

	Government of Telangana HYDERABAD DISASTER RESPONSE AND ASSET PROTECTION AGENCY Renewal Fire No Objection Certificate	
---	--	---

From: The Commissioner, Hyderabad Disaster Response and Asset Protection Agency (HYDRAA)	To: LAKSHYA SCHOOL,	
--	-------------------------------	---

Acknowledgement No. HYDRAA0000952026, Dated: 27-08-2026

Sir,

Sub: HYDRAA – Disaster Management Wing - Issuance of Renewal Fire No Objection Certificate for the existing Non High-Rise Building consisting of Ground + 3 Upper Floors at Sy.No:38/? 2 , Saheb Nagar Kalan(V), Hayat Nagar Mandal,Samanagar,Rangareddy District, belongs to LAKSHYA SCHOOL – Regarding.

* * * * *

Ref:

1. Proceedings Rc.No. 5041/B2/97, Dated: 12.03.2010 of the Director General of the State Disaster Response and Fire Services Department, Andhra Pradesh, Hyderabad.
2. Proceedings No. DM/0011/2018/D(VK) EVDM/2018, dt.29.06.2018 of the Commissioner, GHMC.
3. G.O.Ms.No.99, MA&UD, (GHMC.I) Department, Dt: 19.07.2024.
4. Application of the Management, received through Acknowledgement No. HYDRAA0000952026, dt: 06-08-2026.
5. Inspection report, Dated: 19-08-2026.

1. Proceedings Rc.No. 5041/B2/97, Dated: 12.03.2010 of the Director General of the State Disaster Response and Fire Services Department, Andhra Pradesh, Hyderabad. 2. Proceedings No. DM/0011/2018/D(VK) EVDM/2018, dt.29.06.2018 of the Commissioner, GHMC. 3. G.O.Ms.No.99, MA&UD, (GHMC.I) Department, Dt: 19.07.2024. 4. Application of the Management, received through Acknowledgement No. HYDRAA0000952026, dt: 06-08-2026. 5. Vide reference 5th cited, the team has inspected the site, scrutinized the plans for the Issuance of Renewal Fire No Objection Certificate for the existing Non High-Rise Building consisting of Ground + 3 Upper Floors at Sy.No:38/? 2 , Saheb Nagar Kalan(V), Hayat Nagar Mandal,Samanagar,Rangareddy District, belongs to LAKSHYA SCHOOL and recommended for the Issuance of Renewal Fire No Objection Certificate

1. APPLICANT DETAILS :

1	Name of the Owner	LAKSHYA SCHOOL
2	Father's Name	Karthik Somavarapu
3	Email	karthik.scm@gmail.com
4	Mobile Number	9618156759

2. BUILDING PARTICULARS :

1	Name & Address of the Building	Sy.No:38/? 2 , Saheb Nagar Kalan(V), Hayat Nagar Mandal,Samanagar,Rangareddy District
2	Plot Area (Sq.M)	4586.09
3	Building Height (M)	14.90
4	Abutting Road Width(M)	18

5	No. of Floors	Ground Floor + 3 Upper Floors
6	Commissionerate	Malkajgiri Municipal Corporation
7	Zone	LB Nagar
8	Circle	14 - Hayathnagar
9	Ward	49 - Saheb Nagar

3. CONSULTANT DETAILS :

1	Consultant Name	Karthik Somavarapu
2	Consultant Mobile	9618156759
3	Consultant Email	karthik.scm@gmail.com
4	Consultant Address	Sy.No:38/? 2 , Saheb Nagar Kalan(V), Hayat Nagar Mandal,Samanagar,Rangareddy District

4.OPEN SPACES ALL AROUND THE BUILDING AS PER (G.O.MS.NO.168, DT: 07.04.2012, MA & UD (M) DEPT.) :

Sl.No	Direction	Required (M)	Provided (M)	Deficit (M)	Remarks
1	Front	6	6	0	-
2	Side I	6	6	0	-
3	Side II	6	6	0	-
4	Rear	6	6	0	-

5. FLOOR-WISE DETAILS :

Sl.No	Floor	Area (Sq.M)	Type of Occupancy	Occupancy Description	Max Occupant Load
1	Ground Floor	871.86	Educational (B)	Schools up to senior secondary level (B1)	
2	First Floor	871.86	Educational (B)	Schools up to senior secondary level (B1)	
3	Second Floor	871.86	Educational (B)	Schools up to senior secondary level (B1)	
4	Third Floor	871.86	Educational (B)	Schools up to senior secondary level (B1)	
Total		3,487.44			

6. MEANS OF ESCAPE :

Sl.No	Type of Staircase	Number of Staircases	Width of Staircase (M)	Remarks
1	Internal Staircase	1	1.85	-
2	Internal Staircase	1	1.85	-
Total				3.7

6. FIRE SAFETY INSTALLATION AS PER TABLE-7, PART-IV, N.B.C - 2016 :

Sl.No	Fire Safety Installation	Required	Provided	Deficit
1	Fire Extinguishers	36	36	
2	First Aid Hose Reel	8	08	
3	Manually Operated Electronic Fire Alarm Systems	08	08	
4	Capacity of Terrace Tank over Respective Tower Terrace in Litres	15000	15000	
5	Pump capacity in LPM at the Terrace Tank level with min Pressure of 3.5 Kg/CM ²	450	450	
6	No. of Pumps at the Terrace Tank level with min pressure of 3.5 Kg/Cm ²	1	01	
7	Down Comer	01	01	

8. TERMS & CONDITIONS :

1. The Renewal of Fire NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use / Occupancy or Building Regularization. The Owner / Occupier shall comply the Building Rules / Govt. Orders as applicable.
2. Fixed and first-aid Fire Fighting equipment, alarm etc shall be tested and maintained regularly as per applicable standards and Fire-Drills conducted quarterly for first two years and half yearly after two Years. Also expired equipment should be replaced immediately.
3. Emergency power generator etc., and associated equipment should be tested periodically, verified as per NBC, and IS-1646.
4. Adequate ventilation should be provided in all floors of the building.
5. Evacuation plan showing exit routes and recommended action plan shall be displayed at conspicuous locations and shall be exhibited at all times. All escape / exit routes shall not be blocked or encroached.
6. Fresh NOC would be required for any change in occupancy or additions/alterations in the building structure as per NBC of India and building bye/laws.
7. The Management has to maintain Fire Safety Measures at all times in good working condition as seen during the inspection.
8. Any Loss of life or property due to Non-functioning of Fire Safety Measures and other installations shall be the responsibility of the management/owner.
9. All the Occupants must know the correct method of operation of the First Aid Fire Fighting System installed.
10. All Security personnel shall be trained to operate the Fire Safety Equipment during the Emergency.
11. This Renewal of Fire No Objection Certificate is valid for one (1) year from the date of issue and it is the responsibility of the builder/occupier to apply for the next Renewal, two months before expiry of this Renewal of Fire NOC.
12. The school management shall ensure that, the corridors and staircases shall be kept free without any obstructions/grill doors/locks for safe evacuation of inmates in case of any emergency. The school management shall held responsible if any loss of property/lives due to blockage/obstructions in staircases and corridors.

In view of the above, the **Renewal Fire No Objection Certificate** is Issued for the existing **Non High-Rise Building** consisting of **Ground Floor + 3 Upper Floors** at **Sy.No:38/? 2 , Saheb Nagar Kalan(V), Hayat Nagar Mandal,Samanagar,Rangareddy District**, belongs to **LAKSHYA SCHOOL**, subject to compliance of the above terms and conditions.



**Commissioner,
Hyderabad Disaster Response and
Asset Protection Agency.**

Copies to ;

- 1) The management
- 2) The Inspection Committee

This is a computer-generated document and does not require any stamp or signature.

